

**New Canaan Public Schools
39 Locust Avenue
New Canaan, CT 06840
(203) 594-4000**

RFP #2021-04 Propane Installation - West Elementary School

ADDENDUM 1

Vendors: Please note the following information for RFP #2021-04.

1. BTU specs/rating for existing boilers:
Quantity 2
Smith Cast Iron, Model# 28A-S/W-12
3800 BTU Output
2. BTU specs/rating for existing water heater:
AO Smith, Model# BTH 199A 201
Input BTU/HR maximum 199,900
Input BTU/HR minimum 78,000
3. Contractor to cap off existing feed to water heater and hook up to the new line.
4. Installation of the tanks only may be completed no later than Friday, October 1, 2021.
5. Site drawings of West Elementary School are attached, as requested.